



# EVPÚ<sup>®</sup>

NOTIFIED BODY No. 1293

## EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0265  
of January 18, 2012

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### Addressable smoke detector SensolRIS S130

is an addressable optical-smoke detector designed for installing in addressable fire alarm systems supporting TTE-SensolRIS communication protocol

placed on the market by

**TELETEK ELECTRONICS JSC**  
**14A Srebarňa Str., 1407 Sofia, Bulgaria**

and produced in the factory

**TELETEK ELECTRONICS JSC**  
**14A Srebarňa Str., 1407 Sofia, Bulgaria**


is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

**EN 54-7: 2000/A2: 2006**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on January 18, 2012 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Marek Hudák



040657

Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.